

	महाराष्ट्र शासन यांत्रिकी मंडळ, कोल्हापूर कार्यकारी अभियंता, ताकारी यांत्रिकी व विद्युत विभाग, सांगली वारणाली, विश्रामबाग, सांगली-४१६ ४१५ दूरध्वनी क्र. ०२३३-२३०२९३२ ई-मेल — ee.takarimech@gmail.com	
जा.क्र.तायांवविधिसां/ताशा / १०१३ / सन-२०२६		दिनांक :- २१/०८/२०२६

प्रति,

✓ सी. अधीक्षक अभियंता,
यांत्रिकी मंडळ,
कोल्हापूर


विषय — म्हैसाळ उपसा सिंचन योजना टप्पा क्र. ५ येथे नवीन मोटर पुरवठा करणे करिता बजेटरी ऑफर क्र.७ जाहिरात प्रसिध्द करणे कामाचे परिशिष्ट सादर करणेबाबत.

उपरोक्त विषयास अनुसरून सविनय सादर करणेत येते की, महाराष्ट्रामधील म्हैसाळ उपसा सिंचन योजना टप्पा क्र. ५ येथे नवीन मोटर पुरवठा करणे कामासंबंधित दरसुची तयार करणे काम प्रस्तावित आहे. त्याकरिता सुधारित दर उपलब्ध नसलेने शासन निर्णयानुसार दरसुचीबाह्य घटकभागांचे दर विस्तृत जाहीरातीद्वारे मागवणे आवश्यक आहे.

त्यानुषंगाने सोबत विषयांकित कामाचे परिशिष्ट- बजेटरी ऑफर नोटीस क्र. ७ सादर करणेत येत आहे. महायांत्रिकीच्या संकेतस्थळावर सोबत जोडलेल्या परिशिष्टाप्रमाणे बजेटरी ऑफर नोटीस प्रसिध्दीस देण्यात यावी ही विनंती.

हे आपले माहितीसाठी व पुढील कार्यवाहीस्तव सविनय सादर.

सोबत- बजेटरी ऑफर नोटीस क्र.७ परिशिष्ट


 (वि. व. पाटील)
 कार्यकारी अभियंता,
 ताकारी यांत्रिकी व विद्युत विभाग,
 सांगली

प्रत — कार्यकारी अभियंता, प्रशासन व संगणकीकरण विभाग, कोथरुड, पुणे यांना माहितीसाठी व पुढील कार्यवाहीसाठी सन्नेह अग्रेषित.

२/- सोबतची बजेटरी ऑफर WRD वेबसाईटवर पब्लीश करणेत यावी, हि विनंती.

Government of Maharashtra
Water Resources Department
Superintending Engineer, Mechanical Circle, Kolhapur

Budgetary offer for the following Design, Supply Installation, Testing and Commissioning of the Motor Set For Mhaisai Lift Irrigation Scheme Stage 5 is invited by the Executive Engineer, Takari Mechanical and Electrical Division, Sangli -416 415 Phone No. 0233-2302932 on behalf of Governor of Maharashtra for estimation purpose from the original manufacturer


The details and short specifications for the purchase of machineries/ equipment's are available in the Division Office. Interested Agencies are requested to go through the details and send the budgetary offers for proposed equipment. The rates should cover all taxes and duties applicable. The rates should be given with basic price and tax loading. The interested parties are requested to quote the offer up to 10/9/2026 Further it is requested to forward relevant technical literature, brochures of equipment's and your comments if any in this matter. For detailed specifications of equipment's if required, please contact to this division office.

Sr No	Description.	Quantity in No's
1	Item no 1- Providing, Erecting, testing & trial of Solid Vertical shaft couple with Squirrel Cage Induction Motors CACW F class insulation suitable for operation on voltage mentioned below 3 Phase, 50 Hz with voltage variation +/- 10% and frequency variation +/- 3%, suitable for direct coupling to V.T. pump at Mhaisai stage 5 as per latest revision of IS 325, IS 4722 and other relevant IS specification to meet the power requirement of pumps with 10 % additional capacity over entire operating range. HT Motor: Operating volt- 6.6 KV Minimum Motor O/P rating of 700 kW, motor 500 rpm, and motor efficiency 96 %. Make of Motor KEC /BHEL/ABB/Jeumont / TDP S	1

This information is required for the purpose of preparing working estimates and hence the urgency.

No. TMEDS/TS-1/ 1013 /2026

Office of the Executive Engineer,
Takari Mechanical and electrical Division,
Sangli PIN- 416415
Phone/ fax No. 0233-2302932
e-mail ee.takarimech@gmail.com
Date:- 21/08/2026


(V.V. Patil)
Executive Engineer
Takari Mechanical and electrical Division
Sangli