

	<p>कार्यकारी अभियंता ताकारी यांत्रिकी व विद्युत विभाग वारणाली, सांगली-४१६४१५ यांचे कार्यालय दूरध्वनी क्र.०२३३/२३०२९३२ e-mail: <a href="mailto:ee.takarimech@gmail.com">ee.takarimech@gmail.com</a></p>	
जा.क्र.तायांवि/सांगली/तांशा-१/८३९/सन २०२५	दिनांक- १५.५.२०२५	

प्रति,


मा.अधीक्षक अभियंता,  
यांत्रिकी मंडळ, कोल्हापूर

**विषय -** म्हैसाळ उपसा सिंचन योजनेच्या विविध टप्प्यावरील पंपांची बाऊल असेंब्ली बदलणेसाठीची दरपत्रके मागविणेसाठीची बजेटरी ऑफर प्रसिध्दीस देणेबाबत

उपरोक्त विषयास अनुसरून सविनय सादर करण्यात येते की, या विभागामार्फत सांगली पाटबंधारे मंडळ, सांगली यांचेकडील विविध उपसा सिंचन योजनांच्या परिचलन, देखभाल-दुरुस्तीची कामे केली जातात. सध्या म्हैसाळ उपसा सिंचन योजनेच्या पंपांची कार्यक्षमता कमी झालेने त्यांची दुरुस्ती प्रस्तावित आहे.

त्यास अनुसरून म्हैसाळ उपसा सिंचन योजनेच्या पंपांची कार्यक्षमता वाढविणेच्या दृष्टीने पंपांच्या बाऊल असेंब्ली बदलणे प्रस्तावित आहे. या कामासाठीची दरपत्रके मागविणेसाठीची बजेटरी ऑफर नोटीस मंडळ कार्यालयामार्फत प्रसिध्दीस देणेसाठी सोबत सादर करणेत येत आहे. तरी सोबत जोडलेल्या अनुसूचीप्रमाणे बजेटरी ऑफर नोटीस प्रसिध्दीस देण्यात यावी, ही विनंती.

**सोबत-** बजेटरी ऑफर नोटीस

  
(आ.ना.मोरे)

कार्यकारी अभियंता  
ताकारी यांत्रिकी व विद्युत विभाग  
वारणाली-सांगली

**प्रत-** उप अभियंता, ताकारी यांत्रिकी उप विभाग क्र.१, सांगली यांना माहितीसाठी रवाना.

**Government of Maharashtra**

**Water Resources Department**

**Superintending Engineer, Mechanical Circle, Kolhapur**

Budgetary offer for the following work (*Non DSR items*) are invited by the Executive Engineer, Takari Mechanical and Electrical Division, Sangli on behalf of Governor of Maharashtra for estimation purpose from the reputed Manufacturers/Suppliers/Job Workers.

The Government of Maharashtra, Water Resources Department, has undertaken the various Lift Irrigation Schemes. In context to this, we propose to refurbish the Kirloskar VT pumps by replacing the bowl assembly with new components as mentioned in schedule attached. The details and short specifications of work are available on the website mentioned below.

It is requested to send the budgetary offer mentioning item wise and complete rate with rate analysis for the same. The rates will cover all taxes and duties applicable. The offer should reach this office on or before **04.06.2025** by **e-mail, post or courier**. Further it is requested to forward relevant Technical literature, brochures and your comments if any.

<b>Sr. No.</b>	<b>Name of work</b>	<b>Remarks</b>
1	Refurbishment of Kirloskar VT pumps at Mhaisal LIS Stage 3 by replacing the bowl assembly with new components to restore the pump efficiency: - Make: Kirloskar - Pump Type: Vertical Turbine Pump - HP: 652 - Head: 22.12 meters - Capacity/Discharge per pump: 1.972 m3/sec - Power: 536 kW - RPM: 500	
2	Refurbishment of Kirloskar VT pumps at Mhaisal LIS Stage 4 by replacing the bowl assembly with new components to restore the pump efficiency: - Make: Kirloskar - Pump Type: Vertical Turbine Pump - HP: 960 - Head: 39 meters - Capacity/Discharge per pump: 1.644 m3/sec - Power: 788 kW - RPM: 750	Please refer Website for detailed Schedule
3	Refurbishment of Kirloskar VT pumps at Mhaisal LIS Stage 5 by replacing the bowl assembly with new components to restore the pump efficiency: - Make: Kirloskar - Pump Type: Vertical Turbine Pump - HP: 772 - Head: 23 meters - Capacity/Discharge per pump: 2.240 m3/sec - Power: 634 kW - RPM: 500	

**Note:** Please quote your rates for each item separately inclusive of material, machinery and labour and transportation charges etc. mentioning GST separately

These rates are required for the purpose of framing of working estimates and hence the urgency. This Budgetary offer is also available on website [www.mahayantriki.org](http://www.mahayantriki.org).

Manufacturers/Suppliers/Job Workers is requested to act in given time frame.

No. TMED/Sangli/TS-1/**839**/of 2025  
Office of the Executive Engineer,  
Takari Mechanical and Electrical Division,  
Sangli - 416415  
Telephone No.: 0233/2302932  
e-mail: ee.takarimech@gmail.com

**Date: 15.05.2025**



(A.N.More)

**Executive Engineer**  
**Takari Mechanical and Electrical Division**  
**Sangli**

**Copy** submitted to the Superintending Engineer, Mechanical Circle, Kolhapur for favor of information please.

*Enclosure: Schedule*

**Copy** forwarded to Deputy Engineer, Takari Mechanical Sub Division No.1, Sangli.

*Enclosure: Schedule*

**SCHEDULE-1**

**Budgetary Offer for Refurbishment of Kirloskar make VT Pumps at Mhaisal LIS Stage-3**

<i>Sr. No.</i>	<i>Description</i>	<i>Qty.</i>	<i>Unit</i>	<i>Rate (Rs.)</i>	<i>Amount (Rs.)</i>
1	Refurbishment of Kirloskar make VT pumps at Mhaisal Stage-3 of following duties which includes replacement of full bowl assembly, transmission shafts with sleeves, muff couplings, transmission bearing, thrust bearing etc. <b>(The detailed spare list is as per Annexure-1)</b> <b><u>Pump Details:</u></b> - Make: Kirloskar - Pump Type: Vertical Turbine Pump - HP: 652                      - Head: 22.12 meters - Capacity/Discharge per pump: 1.972 m3/sec - Power: 536 kW   - RPM: 500 <b><u>Our scope of work includes:</u></b>	4	No.		
	1. Dis-assembly and Inspection: Careful dis-assembly of the pump to inspect and identify worn-out parts	1	Job		
	2. Transportation	1	Job		
	3. Supply and Installation of New Bowl Assembly: Supply and installation of new bowl assembly components, including: i) Impeller ii) Diffuser iii) Wear rings iv) Shaft sleeve and v) Other necessary components	1	Job		
	4. Coro coating to pump components	1	Job		
	5. Reassembly and Testing: Reassembly of the pump and testing to ensure the pump efficiency at least 85% (Designed pump efficiency is 91%)	1	Job		
	6. Commissioning: Commissioning of the refurbished pump to ensure smooth operation at work site	1	Job		
	7. Any other costs (specify)	1	Job		
2	<b><u>HT Motor:</u></b> Supply, installation and commissioning at site of works and testing to full capacity, Solid shaft, squirrel cage induction motors CACW type 'F' class installation suitable for operation on voltage mentioned below 3 phase 50 Hz energy efficient with voltage variation of +10% and frequency variation + 3% suitable for direct coupling with pumps under item No.1 as per latest revision of IS 325, IS 4722 and other relevant IS specifications. Suitable for following duties, specifications and confirming to detailed specifications: Operating voltage: 6.6 kV Minimum (KW) rating of motor: 634 kW RPM: 500	1	No.		
	<b>Total cost Rs.</b>				
	<b>Add GST @ .... %</b>				
	<b>Gross Total Rs.</b>				

**Terms and Conditions:**

1. Work is to be executed at Mhaisal LIS Stage 3 Tal - Miraj, Dist - Sangli.

2. The rates quoted should be item wise and exclusive of GST.
3. The material should be as per relevant IS specification.
4. This budgetary offer is called for estimation purpose only.
5. Please mention approximate weight of bowl assembly.
6. Please submit performance curve with offer for given duties.



(A.N.More)

**Executive Engineer**  
**Takari Mechanical and Electrical Division**  
**Sangli**

**SCHEDULE-2**

**Budgetary Offer for Refurbishment of Kirloskar make VT Pumps at Mhaisal LIS Stage-4**

<i>Sr. No.</i>	<i>Description</i>	<i>Qty.</i>	<i>Unit</i>	<i>Rate (Rs.)</i>	<i>Amount (Rs.)</i>
1	Refurbishment of Kirloskar make VT pumps at Mhaisal Stage-4 of following duties which includes replacement of full bowl assembly, transmission shafts with sleeves, muff couplings, transmission bearing, thrust bearing etc. <b>(The detailed spare list is as per Annexure-1)</b> <b><u>Pump Details:</u></b> - Make: Kirloskar - Pump Type: Vertical Turbine Pump - HP: 960 - Head: 39 meters - Capacity/Discharge per pump: 1.644 m <sup>3</sup> /sec - Power: 788 kW - RPM: 750  Our scope of work includes:	4	No.		
	1. Dis-assembly and Inspection: Careful dis-assembly of the pump to inspect and identify worn-out parts	1	Job		
	2. Transportation	1	Job		
	3. Supply and Installation of New Bowl Assembly: Supply and installation of new bowl assembly components, including: i) Impeller ii) Diffuser iii) Wear rings iv) Shaft sleeve and v) Other necessary components	1	Job		
	4. Coro coating to pump components	1	Job		
	5. Reassembly and Testing: Reassembly of the pump and testing to ensure the pump efficiency at least 85% (Designed pump efficiency is 91%)	1	Job		
	6. Commissioning: Commissioning of the refurbished pump to ensure smooth operation at work site	1	Job		
	7. Any other costs (specify)	1	Job		
				<b>Total cost Rs.</b>	
				<b>Add GST @ .... %</b>	
				<b>Gross Total Rs.</b>	

**Terms and Conditions:**

1. Work is to be executed at Mhaisal LIS Stage 4 Tal - Miraj, Dist - Sangli.
2. The rates quoted should be item wise and exclusive of GST.
3. The material should be as per relevant IS specification.
4. This budgetary offer is called for estimation purpose only.
5. Please mention approximate weight of bowl assembly.
6. Please submit performance curve with offer for given duties.



(A.N. More)

**Executive Engineer**

**Takari Mechanical and Electrical Division  
Sangli**


### SCHEDULE-3

#### Budgetary Offer for Refurbishment of Kirloskar make VT Pumps at Mhaisal LIS Stage-5

<i>Sr. No.</i>	<i>Description</i>	<i>Qty.</i>	<i>Unit</i>	<i>Rate (Rs.)</i>	<i>Amount (Rs.)</i>
1	Refurbishment of Kirloskar make VT pumps at Mhaisal Stage-5 of following duties which includes replacement of full bowl assembly, transmission shafts with sleeves, muff couplings, transmission bearing, thrust bearing etc. <b>(The detailed spare list is as per Annexure-1)</b> <b><u>Pump Details:</u></b> - Make: Kirloskar - Pump Type: Vertical Turbine Pump - HP: 772 - Head: 23 meters - Capacity/Discharge per pump: 2.240 m <sup>3</sup> /sec - Power: 634 kW - RPM: 500  <b><u>Our scope of work includes:</u></b>	4	No.		
	1. Dis-assembly and Inspection: Careful dis-assembly of the pump to inspect and identify worn-out parts	1	Job		
	2. Transportation	1	Job		
	3. Supply and Installation of New Bowl Assembly: Supply and installation of new bowl assembly components, including: i) Impeller ii) Diffuser iii) Wear rings iv) Shaft sleeve and v) Other necessary components	1	Job		
	4. Coro coating to pump components	1	Job		
	5. Reassembly and Testing: Reassembly of the pump and testing to ensure the pump efficiency at least 85% (Designed pump efficiency is 91%)	1	Job		
	6. Commissioning: Commissioning of the refurbished pump to ensure smooth operation at work site	1	Job		
	7. Any other costs (specify)	1	Job		
				<b>Total cost Rs.</b>	
				<b>Add GST @ .... %</b>	
				<b>Gross Total Rs.</b>	

#### **Terms and Conditions:**

1. Work is to be executed at Mhaisal LIS Stage-5 Tal - Miraj, Dist - Sangli.
2. The rates quoted should be item wise and exclusive of GST.
3. The material should be as per relevant IS specification.
4. This budgetary offer is called for estimation purpose only.
5. Please mention approximate weight of bowl assembly.
6. Please submit performance curve with offer for given duties.

  
(A.N. More)

**Executive Engineer**  
**Takari Mechanical and Electrical Division**  
**Sangli**

## Annex 1

## Refurbishment of pumps @ Mhaisal stage 3.

Sr. No.	Work description	Qty / pump Stage 3
1	Dismantling of existing pump	
2	Manufacture & supply following spares	
a	Taper Pipe	1
b	Flange pair	1
c	Journal brg	1
d	Distance sleeve	1
e	Bowl	1
f	Transmission Shaft	1
g	Impeller shaft	1
h	Shaft sleeve	6
i	Muff coupling	6
j	Gland sleeve	1
k	Impeller sleeve	1
l	Key	9
m	Impeller wear ring	1
n	Impeller nut, lock nut tc	1
o	Fastners	1200 Kg
p	Impeller	1
q	Head Shaft	1
r	Transmission bearing	6
s	Bearing bush	1
t	Bowl bearing	1
u	Casing wear ring	1
v	Sleeve nut	1
3	Factory test of pump with new bowl unit	
4	Reconditioning of all other spares & painting to column pipes internally & externally	
5	Assembling pump & give test trial	
6	Carry out performance test on site	





KIRLOSKAR BROTHERS LTD. KIRLOSKARWADI (INDIA) NO.


PERFORMANCE CURVE OF PUMP BHRT15-1STGS

SUC. 0 mm DELI 200 mm

This curve relates to the liquid of S.G. 1.000 viscosity AS WATER

PUMP NO. 153800112

DUTY POINT IS GUARANTEED AS PER IS 9137





DISCHARGE Q IN m³/hr

CLIENT	M.K.V.D.C.	GUARANTEED DUTY POINT
PROJECT	MHAISAL L.I.S. STAGE-III	BOWL HEAD H 22.120 m
SERVICE	RAW WATER	DISCHARGE Q 7124.40 m³/hr
CONSULTANT / INDENTOR		BOWL INPUT N 471.610 kW
		BOWL EFFI. ? 91.00 %
		REQD. NPSH 0.00 m
		MIN. SUBMERGENCE 2.000 m
		RECOMENDED PRIME MOVER 536.0 kW
		FULL LOAD SPEED 492 rpm










FILE NO.

O/A NO./ITEM NO. - 15WOF792 / 2.00 dt.29/02/2000  
 IMPELLER DIA./MAT. - 1010 mm / CA6NM



- 502 M.S. IS 3877-PF 300 CALV.
- 503 WOOD
- 370 MATHURON RUBBER
- 371 NEOPRENE RUBBER
- 243 ST ST ASTMA 278-410 ANTD
- 242 ST ST ASTMA 278-410 ANTD
- 222 ST ST ASTMA 278-410 ANTD
- 110 BR 12-30-11 B3
- 115 BR 12-30-11 B3
- 023 CS 1527 F 410 C 8
- 024 CS 1527 F 410 C 8
- 025 CS 1527 F 410 C 8
- 026 CS 1527 F 410 C 8
- 027 CS 1527 F 410 C 8
- 028 CS 1527 F 410 C 8
- 029 CS 1527 F 410 C 8
- 030 CS 1527 F 410 C 8
- 031 CS 1527 F 410 C 8
- 032 CS 1527 F 410 C 8
- 033 CS 1527 F 410 C 8
- 034 CS 1527 F 410 C 8
- 035 CS 1527 F 410 C 8
- 036 CS 1527 F 410 C 8
- 037 CS 1527 F 410 C 8
- 038 CS 1527 F 410 C 8
- 039 CS 1527 F 410 C 8
- 040 CS 1527 F 410 C 8
- 041 CS 1527 F 410 C 8
- 042 CS 1527 F 410 C 8
- 043 CS 1527 F 410 C 8
- 044 CS 1527 F 410 C 8
- 045 CS 1527 F 410 C 8
- 046 CS 1527 F 410 C 8
- 047 CS 1527 F 410 C 8
- 048 CS 1527 F 410 C 8
- 049 CS 1527 F 410 C 8
- 050 CS 1527 F 410 C 8
- 051 CS 1527 F 410 C 8
- 052 CS 1527 F 410 C 8
- 053 CS 1527 F 410 C 8
- 054 CS 1527 F 410 C 8
- 055 CS 1527 F 410 C 8
- 056 CS 1527 F 410 C 8
- 057 CS 1527 F 410 C 8
- 058 CS 1527 F 410 C 8
- 059 CS 1527 F 410 C 8
- 060 CS 1527 F 410 C 8
- 061 CS 1527 F 410 C 8
- 062 CS 1527 F 410 C 8
- 063 CS 1527 F 410 C 8
- 064 CS 1527 F 410 C 8
- 065 CS 1527 F 410 C 8
- 066 CS 1527 F 410 C 8
- 067 CS 1527 F 410 C 8
- 068 CS 1527 F 410 C 8
- 069 CS 1527 F 410 C 8
- 070 CS 1527 F 410 C 8
- 071 CS 1527 F 410 C 8
- 072 CS 1527 F 410 C 8
- 073 CS 1527 F 410 C 8
- 074 CS 1527 F 410 C 8
- 075 CS 1527 F 410 C 8
- 076 CS 1527 F 410 C 8
- 077 CS 1527 F 410 C 8
- 078 CS 1527 F 410 C 8
- 079 CS 1527 F 410 C 8
- 080 CS 1527 F 410 C 8
- 081 CS 1527 F 410 C 8
- 082 CS 1527 F 410 C 8
- 083 CS 1527 F 410 C 8
- 084 CS 1527 F 410 C 8
- 085 CS 1527 F 410 C 8
- 086 CS 1527 F 410 C 8
- 087 CS 1527 F 410 C 8
- 088 CS 1527 F 410 C 8
- 089 CS 1527 F 410 C 8
- 090 CS 1527 F 410 C 8
- 091 CS 1527 F 410 C 8
- 092 CS 1527 F 410 C 8
- 093 CS 1527 F 410 C 8
- 094 CS 1527 F 410 C 8
- 095 CS 1527 F 410 C 8
- 096 CS 1527 F 410 C 8
- 097 CS 1527 F 410 C 8
- 098 CS 1527 F 410 C 8
- 099 CS 1527 F 410 C 8
- 100 CS 1527 F 410 C 8

REV. NO.	DESCRIPTION	DATE	BY	CHECKED
1	ISSUED FOR MANUFACTURE	15/07/2000	...	...
2	...	...	...	...
3	...	...	...	...
4	...	...	...	...
5	...	...	...	...
6	...	...	...	...
7	...	...	...	...
8	...	...	...	...
9	...	...	...	...
10	...	...	...	...
11	...	...	...	...
12	...	...	...	...
13	...	...	...	...
14	...	...	...	...
15	...	...	...	...
16	...	...	...	...
17	...	...	...	...
18	...	...	...	...
19	...	...	...	...
20	...	...	...	...
21	...	...	...	...
22	...	...	...	...
23	...	...	...	...
24	...	...	...	...
25	...	...	...	...
26	...	...	...	...
27	...	...	...	...
28	...	...	...	...
29	...	...	...	...
30	...	...	...	...
31	...	...	...	...
32	...	...	...	...
33	...	...	...	...
34	...	...	...	...
35	...	...	...	...
36	...	...	...	...
37	...	...	...	...
38	...	...	...	...
39	...	...	...	...
40	...	...	...	...
41	...	...	...	...
42	...	...	...	...
43	...	...	...	...
44	...	...	...	...
45	...	...	...	...
46	...	...	...	...
47	...	...	...	...
48	...	...	...	...
49	...	...	...	...
50	...	...	...	...
51	...	...	...	...
52	...	...	...	...
53	...	...	...	...
54	...	...	...	...
55	...	...	...	...
56	...	...	...	...
57	...	...	...	...
58	...	...	...	...
59	...	...	...	...
60	...	...	...	...
61	...	...	...	...
62	...	...	...	...
63	...	...	...	...
64	...	...	...	...
65	...	...	...	...
66	...	...	...	...
67	...	...	...	...
68	...	...	...	...
69	...	...	...	...
70	...	...	...	...
71	...	...	...	...
72	...	...	...	...
73	...	...	...	...
74	...	...	...	...
75	...	...	...	...
76	...	...	...	...
77	...	...	...	...
78	...	...	...	...
79	...	...	...	...
80	...	...	...	...
81	...	...	...	...
82	...	...	...	...
83	...	...	...	...
84	...	...	...	...
85	...	...	...	...
86	...	...	...	...
87	...	...	...	...
88	...	...	...	...
89	...	...	...	...
90	...	...	...	...
91	...	...	...	...
92	...	...	...	...
93	...	...	...	...
94	...	...	...	...
95	...	...	...	...
96	...	...	...	...
97	...	...	...	...
98	...	...	...	...
99	...	...	...	...
100	...	...	...	...




Generally Approved.  
B. Ramani

Annex 1  
Refurbishment of pumps @ Mhaisal stage 4.




Sr. No.	Work description	Qty / pump
		Stage 4
1	Dismantling of existing pump	
2	Manufacture & supply following spares	
a	Taper Pipe	1
b	Flange pair	1
c	Journal brg	1
d	Distance sleeve	1
e	Bowl	1
f	Transmission Shaft	1
g	Impeller shaft	1
h	Shaft sleeve	7
i	Muff coupling	7
j	Gland sleeve	1
k	Impeller sleeve	1
l	Key	11
m	Impeller wear ring	1
n	Impeller nut, lock nut tc	1
o	Fastners	1000 Kg
p	Impeller	1
q	Head Shaft	1
r	Transmission bearing	7
s	Bearing bush	1
t	Bowl bearing	1
u	Casing wear ring	1
v	Sleeve nut	1
3	Factory test of pump with new bowl unit	
4	Reconditioning of all other spares & painting to column pipes internally & externally	
5	Assembling pump & give test trial	
6	Carry out performance test on site	

1) IN THE EVENT THE POINT IS NOT SHOWN IN THE DRAWING THE POINT IS TO BE TAKEN AS SHOWN IN THE PHOTOGRAPH ATTACHED TO THE DRAWING.



CODE	DESCRIPTION
502	MS IS 1877-36 310 GALV.
374	MS IS 1877-36 310 GALV.
370	MS IS 1877-36 310 GALV.
372	MS IS 1877-36 310 GALV.
376	MS IS 1877-36 310 GALV.
378	MS IS 1877-36 310 GALV.
380	MS IS 1877-36 310 GALV.
382	MS IS 1877-36 310 GALV.
384	MS IS 1877-36 310 GALV.
386	MS IS 1877-36 310 GALV.
388	MS IS 1877-36 310 GALV.
390	MS IS 1877-36 310 GALV.
392	MS IS 1877-36 310 GALV.
394	MS IS 1877-36 310 GALV.
396	MS IS 1877-36 310 GALV.
398	MS IS 1877-36 310 GALV.
400	MS IS 1877-36 310 GALV.
402	MS IS 1877-36 310 GALV.
404	MS IS 1877-36 310 GALV.
406	MS IS 1877-36 310 GALV.
408	MS IS 1877-36 310 GALV.
410	MS IS 1877-36 310 GALV.
412	MS IS 1877-36 310 GALV.
414	MS IS 1877-36 310 GALV.
416	MS IS 1877-36 310 GALV.
418	MS IS 1877-36 310 GALV.
420	MS IS 1877-36 310 GALV.
422	MS IS 1877-36 310 GALV.
424	MS IS 1877-36 310 GALV.
426	MS IS 1877-36 310 GALV.
428	MS IS 1877-36 310 GALV.
430	MS IS 1877-36 310 GALV.
432	MS IS 1877-36 310 GALV.
434	MS IS 1877-36 310 GALV.
436	MS IS 1877-36 310 GALV.
438	MS IS 1877-36 310 GALV.
440	MS IS 1877-36 310 GALV.
442	MS IS 1877-36 310 GALV.
444	MS IS 1877-36 310 GALV.
446	MS IS 1877-36 310 GALV.
448	MS IS 1877-36 310 GALV.
450	MS IS 1877-36 310 GALV.
452	MS IS 1877-36 310 GALV.
454	MS IS 1877-36 310 GALV.
456	MS IS 1877-36 310 GALV.
458	MS IS 1877-36 310 GALV.
460	MS IS 1877-36 310 GALV.
462	MS IS 1877-36 310 GALV.
464	MS IS 1877-36 310 GALV.
466	MS IS 1877-36 310 GALV.
468	MS IS 1877-36 310 GALV.
470	MS IS 1877-36 310 GALV.
472	MS IS 1877-36 310 GALV.
474	MS IS 1877-36 310 GALV.
476	MS IS 1877-36 310 GALV.
478	MS IS 1877-36 310 GALV.
480	MS IS 1877-36 310 GALV.
482	MS IS 1877-36 310 GALV.
484	MS IS 1877-36 310 GALV.
486	MS IS 1877-36 310 GALV.
488	MS IS 1877-36 310 GALV.
490	MS IS 1877-36 310 GALV.
492	MS IS 1877-36 310 GALV.
494	MS IS 1877-36 310 GALV.
496	MS IS 1877-36 310 GALV.
498	MS IS 1877-36 310 GALV.
500	MS IS 1877-36 310 GALV.

REV NO.	DESCRIPTION	DATE	BY	CHECKED
1	ISSUED FOR APPROVAL	29/02/2000		
2	ISSUED FOR APPROVAL	29/02/2000		
3	ISSUED FOR APPROVAL	29/02/2000		
4	ISSUED FOR APPROVAL	29/02/2000		
5	ISSUED FOR APPROVAL	29/02/2000		
6	ISSUED FOR APPROVAL	29/02/2000		
7	ISSUED FOR APPROVAL	29/02/2000		
8	ISSUED FOR APPROVAL	29/02/2000		
9	ISSUED FOR APPROVAL	29/02/2000		
10	ISSUED FOR APPROVAL	29/02/2000		




Generally Approved





PERFORMANCE CURVE OF PUMP TYPE BHR 90-1STG  
 This curve relates to the liquid of S.G. 1.0 & viscosity CP/CST

Suc. mm | Del. 100mm.  
 Pump No. 15374000A



CHECKED BY - *[Signature]* / 14/10/00  
 DATE -  
 DRAWN BY - *[Signature]* / 14/10/00  
 DATE -

REQD. NPSH IN METRES-H

NOT TO RUN THE PUMP BELOW .....M TOTAL HEAD

CLIENT M.K.V.D.C  
 PROJECT MHAISAL L-I-S STAGE-IV  
 SERVICE RAW WATER  
 CONSULTANTS/ INDENTOR  
 O/A NO./ITEM NO. :- 15W0F792

GUARANTEED DUTY POINT	
TOTAL HEAD/BOWL HEAD H	39.12 M
DISCHARGE Q	1643.9 / 5918.4 l/s/m³/hr
PUMP INPUT/BOWL INPUT N	692.84 KW
EFFICIENCY PUMP/BOWL η	91 %
REQD. NPSH-	- m
MIN. SUBMERGENCE	1.9 m
ENGINE/MOTOR RATING	788 kW/HP
FULL LOAD SPEED	744 rpm


0X05PADS/04/99

mm/ CA6NM.

Annex 1  
Refurbishment of pumps @ Mhaisal stage 5.

Sr. No.	Work description	Qty / pump Stage 5
1	Dismantling of existing pump	
2	Manufacture & supply following spares	
a	Taper Pipe	1
b	Flange pair	1
c	Journal brg	1
d	Distance sleeve	1
e	Bowl	1
f	Transmission Shaft	1
g	Impeller shaft	1
h	Shaft sleeve	6
i	Muff coupling	6
j	Gland sleeve	1
k	Impeller sleeve	1
l	Key	9
m	Impeller wear ring	1
n	Impeller nut, lock nut tc	1
o	Fastners	1200 Kg
p	Impeller	1
q	Head Shaft	1
r	Transmission bearing	6
s	Bearing bush	1
t	Bowl bearing	1
u	Casing wear ring	1
v	Sleeve nut	1
3	Factory test of pump with new bowl unit	
4	Reconditioning of all other spares & painting to column pipes internally & externally	
5	Assembling pump & give test trial	
6	Carry out performance test on site	



1) DO NOT SCALE THE SHEET AS  
 DIMENSIONS ARE TO BE TAKEN FROM  
 ORIGINAL DRAWING. 2) DIMENSIONS  
 ARE IN MILLIMETERS UNLESS  
 OTHERWISE SPECIFIED. 3) THE  
 DIMENSIONS ARE TO BE TAKEN FROM  
 ORIGINAL DRAWING.



CODE	DESCRIPTION
502	MS IS 1977-78 310 GALV.
571	NATURAL RUBBER
572	NATURAL RUBBER
573	NATURAL RUBBER
574	NATURAL RUBBER
575	NATURAL RUBBER
576	NATURAL RUBBER
577	NATURAL RUBBER
578	NATURAL RUBBER
579	NATURAL RUBBER
580	NATURAL RUBBER
581	NATURAL RUBBER
582	NATURAL RUBBER
583	NATURAL RUBBER
584	NATURAL RUBBER
585	NATURAL RUBBER
586	NATURAL RUBBER
587	NATURAL RUBBER
588	NATURAL RUBBER
589	NATURAL RUBBER
590	NATURAL RUBBER
591	NATURAL RUBBER
592	NATURAL RUBBER
593	NATURAL RUBBER
594	NATURAL RUBBER
595	NATURAL RUBBER
596	NATURAL RUBBER
597	NATURAL RUBBER
598	NATURAL RUBBER
599	NATURAL RUBBER
600	NATURAL RUBBER

REV. NO.	DESCRIPTION	DATE
01	ISSUED FOR APPROVAL	15/07/92
02	REVISION	28/02/2000

CROSS SECTIONAL ASSEMBLY  
 STAGE - V SERVS : 10  
 CLIENT : EXECUTIVE ENGINEER  
 PROJECT : MHSAL STAGE III/IV L.S.  
 DRAWN BY : RAVI VAITHY  
 CHECKED BY :  
 APPROVED BY :  
 KIRDOSKAR BROTHERS LIMITED  
 HEAD OFFICE : 150, MARKET STREET, CHENNAI - 600 002  
 BRANCH OFFICE : 150, MARKET STREET, CHENNAI - 600 002  
 TEL : 044-2423 0000  
 FAX : 044-2423 0000  
 E-MAIL : kirdoskar@vsnl.com



Generally Approved

KIRLOSKAR BROTHERS LTD. KIRLOSKARWADI (INDIA)

NO.


PERFORMANCE CURVE OF PUMP BHR115

SUC. 0 mm DEL. 1200 mm

This curve relates to the liquid of S.G. 1.000 viscosity AS WATER

PUMP NO. 153800119

DUTY POINT IS GUARANTEED AS PER IS 9137



DISCHARGE Q IN m<sup>3</sup>/hr

CLIENT	M.K.V.D.C.	// GUARANTEED DUTY POINT	
PROJECT	MHAISAL L.I.S. STAGE-V	BOWL HEAD H	23.190 m
SERVICE	RAW WATER	DISCHARGE Q	8064.00 m <sup>3</sup> /hr
CONSULTANT / INDENTOR		BOWL INPUT N	559.640 kW
		BOWL EFFI. η	91.00 %
		REQD. NPSH	0.00 m
O/A NO./ITEM NO. - 15WOF792 / 47.00	dt. 29/02/2000	MIN. SUBMERGENCE	2.000 m
IMPELLER DIA./MAT. - mm / CA6NM		RECOMENDED PRIME MOVER	634.0 kW
		FULL LOAD SPEED	492 rpm