



**Government of Maharashtra**  
**Water resources Department Executive Engineer**  
**Office of the Executive Engineer, Vishnupuri Pumphouse Division Nanded.**

**Address: Executive Engineer, Vishnupuri Pumphouse Division Nanded. 431605 .**

**Email: [yphdn@redffmail.com](mailto:yphdn@redffmail.com) Office Telephone No. 02462-260738**

**Budgetary Offer Notice No. 02/2025-26**

**Name Of Work :-** Designing Manufacturing, Providing, Erecting, Testing, Commissioning of **Rubber Expansion Joint** Fitting to delivery pipe line of pump suitable for 800 mm dia. Delivery pipe as per detail specifications.

Executive Engineer, Vishnupuri Pump House Division, Nanded invites Budgetary offer of above mentioned work for estimation purpose only. Those recognized original Equipment Manufacturers working in above mentioned work are requested to submit their budgetary offers by post or email upto dt. 22/07/2025 at 05:00 pm to this office. Please visit for Departments website [www.wrd.maharashtra.gov.in](http://www.wrd.maharashtra.gov.in) for detail specifications.

Budgetary Offer Online Display Date :- 15/07/2025.

Budgetary Offer Submission Date:- 22/07/2025

Terms & Conditions :-

1. Budgetary Offer has been invited for estimation purpose only
2. Budgetary Offer rates should be exclusive of GST & valied for one year.
3. Budgetary Offer rates should be inclusive of transportation & damage charges.

*(Handwritten Signature)*

**(D.R.SAWANT)**

**Executive Engineer**  
**Vishnupuri Pump House Division**  
**Nanded.**

## SPECIFICATION FOR BUDGETORY OFFER

**Name of Work:** Designing Manufacturing, Providing, Erecting, Testing, Commissioning of Rubber Expansion Joint fitting to pump delivery pipe line suitable for 800 mm dia. Delivery pipe including Tie Rod and Clamping set. as per detail specifications at Uppar Manar Lift irrigation Scheme Tq. Ahmadpur Dist.Latur.

Sr.No	Short Description	Unit	Qty	Rate	Amount
ITEM NO. 1	Designing Manufacturing, Providing, Erecting, Testing, Commissioning of Rubber Expansion Joint fitting to pump delivery pipe line suitable for 800 mm dia. Delivery pipe including Tie Rod and Clamping set. Specification: 1) Diameter:800 mm 2) Internal Test Pressure: 15 kg/cm <sup>2</sup> . 3) Vaccum Pressure: 700 mm of Mercury.(0.95 kg/cm <sup>2</sup> ). 4) P.N Rating: 1.00	Nos	1		



(N.D.Pisute)

Deputy Engineer  
Mechanical Sub-Div(V.P)  
Nanded.



(D.R.Sawant)

Executive Engineer  
Vishnupuri Pump House Division  
Nanded.