



महाराष्ट्र शासन
जलसंपदा विभाग
बजेटरी ऑफर क्र. ०५/सन २५-२६

पत्ता- कार्यकारी अभियंता यांत्रिकी विभाग अमरावती

ई-मेल - mechdamt@gmail.com

कार्यकारी अभियंता यांत्रिकी विभाग अमरावती , जलसंपदा विभाग महाराष्ट्र शासन हे सक्षम कंत्राटदाराकडून/ पुरवठादाराकडून या कार्यालयास अंदाजपत्रक तयार करण्यासाठी बजेटरी ऑफर मागविण्यात येत आहे. बजेटरी ऑफर विस्तृतपणे (सर्व माहिती) शासनाचे संकेत स्थळ wrd.maharashtra.gov.in यावर उपलब्ध आहे. बजेटरी ऑफर स्विकारण्याचा अथवा नाकारण्याचा अधिकार कार्यकारी अभियंता यांत्रिकी विभाग अमरावती यांनी राखून ठेवला आहे. अट असलेल्या बजेटरी ऑफर स्विकारल्या जाणार नाही. बजेटरी ऑफर या कार्यालयाच्या email id वर स्वीकारण्यात येतील.

अ.क्र.	बजेटरी ऑफरचे वर्णन	संख्या	बजेटरी ऑफर पाठविण्याच ठिकाण	बजेटरी ऑफर करिता महत्वाच्या दिनांक
१.	Budgetary offer being called by Executive Engineer Mechanical Division Amravati for Dehani LIS Taq. Bhabulgaon , Dist. Yavatmal. Item No. 1:- Design, Supply, Erection and Commissioning of Self Cleaning Automatic Primary Filtration System of 300 Micron having Filter Body Housing of Epoxy Coated Carbon Steel, Screen of SS 316, Seals of NBR/EPDM at Intake or Any Suitable Pump House comprises of Self Cleaning Automatic Brush filter Assembly with Inlet/Outlet Isolation Valve for Filter, DPCV on Outlet of Filter, Dismantling Joints, Instruments Control and Power Cable, Flushing Line, Inlet/Outlet Manifold with Tee, Bends, Connection to Mainline, Local Control Panel, Companion Flanges, Fastner, Gasket, Civil Work etc. complete suitable for the flow rate of 4400 LPS. Filter Unit should have Bottom Drain Facility to remove the Heavy Suspended Solids/Big Particles. Rates including all lead & lifts .(Excluding GST	1	कार्यालय कार्यकारी अभियंता, यांत्रिकी विभाग, जलसंपदा परिसर, जेल रोड, अमरावती — ४४४६०२	बजेटरी ऑफर्स कार्यालयात सादर करण्याचा कालावधी :- ५ दिवस दि. ६/१०/२०२५ सकाळी ११ ते दि.१०/१०/२०२५ संध्याकाळी ५ वाजेपर्यंत

	and Insurance).			
	Item No. 2:- Design, Supply, Erection and Commissioning of Self Cleaning Automatic Primary Filtration System of 300 Micron having Filter Body Housing of Epoxy Coated Carbon Steel, Screen of SS 316, Seals of NBR/EPDM at Intake or Any Suitable Pump House comprises of Self Cleaning Automatic Brush filter Assembly with Inlet/Outlet Isolation Valve for Filter, DPCV on Outlet of Filter, Dismantling Joints, Instruments Control and Power Cable, Flushing Line, Inlet/Outlet Manifold with Tee, Bends, Connection to Mainline, Local Control Panel, Companion Flanges, Fastner, Gasket, Civil Work etc. complete suitable for the flow rate of 1240 LPS. Filter Unit should have Bottom Drain Facility to remove the Heavy Suspended Solids/Big Particles. Rates including all lead & lifts . (Excluding GST and Insurance) Item No. 3:- Design, Supply, Erection and Commissioning of Self Cleaning Automatic Secondary Filtration System of 200 Micron having Filter Body Housing of Epoxy Coated Carbon Steel, Screen of SS 316, Seals of NBR/EPDM at SDC Pump House comprises of Self Cleaning Automatic Brush filter Assembly with Inlet/Outlet Isolation Valve for Filter, DPCV on Outlet of Filter, Dismantling Joints, Instruments Control and Power Cable, Flushing Line, Inlet/Outlet Manifold with Tee, Bends, Connection to Mainline, Local Control Panel, Companion Flanges, Fastner, Gasket, Civil Work etc. complete suitable for the flow rate of 110 LPS. Rates including all lead & lifts. (Excluding GST and Insurance)	1		बजेटरी उघडण्याचा दिनांक :- दि. १३/१० /२०२५ दुपारी २.०० वाजता.
		57		

	The details are also available on website wrd.maharashtra.gov.in			
--	--	--	--	--

Please Note:-

- 1) Work site location: Tal. Babhulgaon , Dist. Yavatmal, approx. 25 KM from Yavatmal Town.
- 2) E-Quotations are invited only for the estimation purpose. It does not give any assurance regarding tender or work.
- 3) Right to reject any or all the quotations without assigning any reasons reserved.

Terms and Conditions: -

- 1) The rates for said work shall be exclusive of GST
- 2) The contractor must attach registration certificate/ experience certificate.
- 3) GST Certificate must be attached along with this E-Quotation.

Eligibility Criteria:-

Agency should have the similar type of work experience of handling minimum one order of having Design, Supply, Erection and Commissioning of Self Cleaning Automatic Primary Filtration System for Pressurize Irrigation System Project in Government sector in any one year. Work done certificate should be certified by office not below the rank of Executive Engineer. Work done certificate should be attached with this quotation.

रूपि दांडे
(नि. पां. खडसे)
कार्यकारी अभियंता
यांत्रिकी विभाग,
अमरावती.